



Arkansas Department of Health

4815 West Markham Street • Little Rock, Arkansas 72205-3867 • Telephone (501) 661-2000

Governor Sarah Huckabee Sanders

Renee Mallory, RN, BSN, Secretary of Health

Jennifer Dillaha, MD, Director

Engineering Section, Slot 37
www.healthy.arkansas.gov/eng

Ph (501) 661-2623 Fax (501) 661-2032
After Hours Emergency (501) 661-2136

November 6, 2025

EDKIN, ROGER
BULL SHOALS WATER SYSTEM
P O BOX 360
BULL SHOALS, AR 72619

RE: BOIL WATER NOTICE LIFT #5838
BULL SHOALS WATER SYSTEM - PWS ID # 352

The Department of Health has released the 'Boil Water' Notice issued on 11/3/2025 by Arkansas Department of Health for the McDonald Meadows and Alford areas. This order was issued as a precautionary measure because of the possibility that contaminated water may have entered the distribution system as a result of a complete loss in normal system pressure and a main break.

Bacteriological samples taken on Tuesday, November 4, 2025 were found to be free of bacterial contamination and a satisfactory disinfectant level has been established throughout the distribution system. The water is therefore considered 'Safe' for human consumption and the 'Boil Water' notice is hereby lifted.

Sincerely,

Mark Jones
Environmental Health Specialist
ADH Engineering Section

BULL SHOALS WATER SYSTEM
MARION

A PRECAUTIONARY BOIL ORDER LIFT

LIFT DATE: NOVEMBER 6, 2025

FOR FURTHER INFORMATION, CONTACT
MARK JONES
ENVIRONMENTAL HEALTH SPECIALIST
ENGINEERING SECTION, (501) 661-2623

NEWS ARTICLE

FOR IMMEDIATE RELEASE

THE DEPARTMENT OF HEALTH HAS HAS RELEASED THE 'BOIL WATER' NOTICE ISSUED ON 11/3/2025 BY ARKANSAS DEPARTMENT OF HEALTH FOR THE MCDONALD MEADOWS AND ALFORD AREAS. THIS ORDER WAS ISSUED AS A PRECAUTIONARY MEASURE BECAUSE OF THE POSSIBILITY THAT CONTAMINATED WATER MAY HAVE ENTERED THE DISTRIBUTION SYSTEM AS A RESULT OF A COMPLETE LOSS IN NORMAL SYSTEM PRESSURE.

BACTERIOLOGICAL SAMPLES TAKEN ON TUESDAY, NOVEMBER 4, 2025 WERE FOUND TO BE 'SAFE' AND A SATISFACTORY DISINFECTANT LEVEL HAS BEEN ESTABLISHED THROUGHOUT THE DISTRIBUTION SYSTEM. THE WATER IS THEREFORE CONSIDERED 'SAFE' FOR HUMAN CONSUMPTION AND THE 'BOIL WATER' NOTICE IS HEREBY LIFTED.

THE BOIL WATER ORDER WAS DUE TO MAIN BREAK.

SYSTEM PERSONNEL NOTIFIED: BY: ON:
SANITARIAN NOTIFIED: Blank|Moore, Scott BY: Mark Jones ON: 11/4/2025 11:21:36 AM