

Bull Shoals wastewater monthly report

November 2024

- Relieved pressure on force main #7 due to faulty air relief valve
- Replaced shorted out U.V connector
- Continuing semiannual oil changes on all Lift stations
- Replaced faulty UPS in disc filter panel
- Received 2.5 MGD between 11/4-11/6
- Filled two SSO reports for overflow of manhole on Golf Course Terrace to ADEQ
- Cleaned up around overflow, disinfected and deodorized
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,204,000 gallons in October

Michael Salentine
Wastewater Supervisor