

Bull Shoals wastewater monthly report

July 2024

- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Rehabbed LS 20 with new pumps and control panel
- Drain clarifier 2 inspect for damage and clean
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Hauled off 20 cu yds of biosolids
- Processed 2 drying beds of biosolids
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,446,000 gallons in July

James Jamieson
Wastewater Supervisor