

# Bull Shoals wastewater monthly report

## June 2024

- General daily plant checks and maintenance
- General facilities housekeeping
- Continued inspections and GPS locating of manholes
- Implemented and began building a GNSS/GIS asset management program for city 's infrastructure
- Starting bid process for cleaning and televising of city's sewer mains and manholes
- Assessed damage from storm began bid process for LS 16 gen set
- Restored all but 1 lift station to 100% operational capacity
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Hauled off 40 cu yds of biosolids
- Processed 4 drying beds of biosolids
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 5,267,000 gallons in March

James Jamieson  
Wastewater Supervisor